

## Attachment F: Sand Filter SCM Inspection Report Town of Knightdale, North Carolina

Project Name: \_\_\_\_\_ Inspection Date: \_\_\_\_\_  
 Parcel PIN: \_\_\_\_\_ SCM ID #: \_\_\_\_\_

**CODE KEY**

<b>NA</b>	Not Applicable
<b>C</b>	Compliant
<b>CM</b>	Compliant with minor maintenance (repairs are to be made within 90 days of initial report)
<b>NC</b>	Not Compliant (Repairs and reinspection within 90 days)

**RESULT:** \_\_\_\_\_

**INFLOW POINTS**

Assessment	Code	Comments
Obstructions (vegetation/debris/sediment)		
Structural Condition of Grates & Covers		
Other (describe)		

**SEDIMENT CHAMBER**

Assessment	Code	Comments
Sediment/Debris Accumulation		
Invasive Vegetation		
Forebay Dam		
Other (describe)		

*\*All applicable OSHA requirements should be followed during inspection.*

**SAND CHAMBER**

Assessment	Code	Comments
Drains < 24 hours after rain event		
Condition of Sand (silt/clay and contaminated sand should be removed and replaced with clean sand)		
Sand Bed Color Profile (if discolored >3" deep, sand must be replaced)		
Sand Bed Has Been Eroded or Displaced		
Vault/Pipe Structural Condition		
Access Ladder/Step Condition		
Debris		
Other (describe)		

*\*All applicable OSHA requirements should be followed during inspection.*

## Attachment F: Sand Filter SCM Inspection Report (Continued)

**OUTLET DEVICE**

Assessment	Code	Comments
Obstruction (vegetation/debris etc.)		
Erosion/Undercutting		
Joint Failure/Loss of Joint Material		
Emergency By-Pass Condition		
Overall Structural Condition		
Other (describe)		

**MISCELLANEOUS**

Assessment	Code	Comments
Access		
Other (describe)		

**ADDITIONAL COMMENTS**


---



---



---



---



---

**PHOTOGRAPHS**

Attach low resolution digital photographs of the site and structural SCMs including captions describing each photo. *NO less than 2 but NO more than 4 photo per page.*