



**NOTES:**

1. EXPANSION JOINTS ARE PERMITTED AT 40' MIN. SPACING AND NOT LESS THAN 12'-6" FROM CENTER OF TREE GRATE.
2. SEE STANDARD DETAIL 4.04 (2 OF 2) FOR GROOVE JOINT.
3. CONCRETE SHALL BE 3600 PSI IN 28 DAYS.
4. ALL REINFORCING STEEL SHALL BE GRADE 60.
5. USE REINFORCED STEEL BAR SUPPORTS IN COMPLIANCE WITH NCDOT STANDARD SPECIFICATION 970-4.

**SECTION C-C**

REVISIONS	
DATE	DESCRIPTION