



TARPS SHALL BE OVERLAPPED AT LEAST 12". THE UPSTREAM 12"
TARP SHALL OVERLAP THE DOWNSTREAM TARP. THE TARP SHALL
BE 50 MIL HEAVY DUTY SILVER TARPAULINS OR EQUIVALENT FOR

3. MAINTENANCE: SEDIMENT TO BE REMOVED AND PROPERLY DISPOSED OF WHEN BASIN IS HALF FULL GRAVEL FILTER AROUND RISER SHOULD BE REPLACED AS NEEDED TO ENSURE DEWATERING.

U.V. RESISTANCE.

STANDARD CUSTOM BASIN

NOTE: ROUND DRAINAGE AREA TO THE NEAREST WHOLE NUMBER TO

DETERMINE NUMBER OF HOLES.

EFFECTIVE: 01/31/08