



Knightdale Fire Department

Fire Marshal's Office

950 Steeple Square Court Knightdale, North Carolina 27545



Fire Hydrant Flow Test

Informational Bulletin

Knightdale Fire Department Fire Marshal's Office requires fire flow data to be submitted during site plan review. In areas connected and served by public fire hydrants, this is completed with the City of Raleigh Fire Department Fire Marshal's Office. To schedule a test, call (919) 996-5972.

In areas connected by private fire hydrants, Knightdale Fire Department Fire Marshal's Office will witness the test performed by a 3rd party vendor of your choice.

1. The testing will need to be scheduled at least one (1) day in advance.
2. The testing will need to be completed using the two-hydrant method.
3. The results of the test will need to be forwarded to our office for review by way of a letter from Professional Engineer or Fire Department records management system.
4. The documentation shall have the date, time, location, hydrant ID, vendor who performed the test and their signature.
5. A fire flow test must have been conducted within the past 12-months; otherwise a new test is required.

